

### Fire Stopping Installation - Record of Installation Activities Form

Client Name	Vivid Homes	Date of issue	01/07/2022
Site Name	22 Edinburgh Road	Project URN	30428
Site address	22 Edinburgh Road, Portsmouth PO1 1DH	Project URN	30428
Qualified Supervisor	E Cox	QS No	1583

Declaration	Signature
I declare that the work undertaken fully complies with the requirements of the Q-Mark Fire Stopping Installation scheme and that the work undertaken complies with Regulations 4 and 7 of the Building Regulations for England and Wales or in accordance with the local regulations in force at the specific job site location.	E Cox

### Fire Stopping Categories

Fire Stop Type	Fire Stop Name	Fire Rating	Component Manufacturer	Component Name
A	Rockwool Acoustic Intumescent Sealant	60	Rockwool	Rockwool Acoustic Intumescent Sealant
B	Rockwool Ablative Coated Batt	60	Rockwool	Rockwool Ablative Coated Batt
C	Rockwool Ablative Liquid	60	Rockwool	Rockwool Ablative Liquid
D	Rockwool High Expansion Intumescent Sealant Grey	60	Rockwool	Rockwool High Expansion Intumescent Sealant Grey
E				
F				
Usage Details	Comments			

As per manufacturer

**Fire Stopping Record**

Fire Stop URN	Fire Stop Type	Installation Date	Installed by	Location Ref
20220629-161	ABCD	29/06/2022	GC	Boiler Room
20220629-161	ABCD	30/06/2022	GC	False Ceiling 1
20220629-170	ABCD	01/07/2022	GC	False Ceiling 2
20220629-170	ABCD	02/07/2022	GC	Electrical Cupboard

**Sample Pictures**



--	--